COMMONWEALTH OF KENTUCKY BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF GREEN-TAYLOR WATER)	
DISTRICT FOR A DEVIATION FROM THE)	CASE NO.
REQUIREMENTS OF 807 KAR 5:066, SECTION)	2000-301
4(4), REGARDING WATER STORAGE)	

<u>ORDER</u>

On June 14, 2000, the Green–Taylor Water District ("Green-Taylor District") applied for permission to deviate from Commission regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Green-Taylor District states in its application that its average daily water usage, including unaccounted-for water, is approximately 750,000 gallons, and that its current water storage capacity is 740,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

- 1. Green-Taylor District is not in compliance with Commission regulation 807 KAR 5:066, Section 4(4).
- 2. Because of the time needed to plan, finance, and construct water storage facilities, Green-Taylor District should be given until July 1, 2005 to comply with 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

- 1. Green-Taylor District is given until July 1, 2005 to comply with the provisions of 807 KAR 5:066, Section 4(4).
- 2. Green-Taylor District shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to July 1, 2005.

Done at Frankfort, Kentucky, this 13th day of July, 2000.

By the Commission

ATTEST:

Executive Director